



Eve Single Pro-line & S-line



EV Charging Stations

Installation Manual

1.	Safety and usage instructions	3
1.1	Disclaimer	3
1.1.1	Improper use	3
1.2	Copyright	3
1.3	Trademarks	3
1.4	Languages	3
1.5	Purpose and intended audience	3
1.6	Explanation of text instructions used	3
1.6.1	Safety symbols	4
1.7	Software and complementary documentation	4
1.8	Operating conditions	5
1.9	EU Declaration of Conformity	5
1.10	About this document	6
2.	Product overview	8
2.1	Scope of delivery	8
2.2	Legend product overview exterior	9
2.3	Legend product overview interior	10
3.	Installing and Connecting	11
3.1	Safety announcements	11
3.2	Assembly and installation requirements	11
3.3	Preparation prior to installation	12
3.4	Installation tools	12
3.5	Installation procedure prerequisites	13
3.5.1	Data cable options	13
3.6	Mechanical installation procedure	13
3.6.1	Wall-mounting the charging station	14
3.7	Electrical installation procedure	24
3.7.1	Additional installation procedure for model with fixed charging cable	26
3.8	Finishing the installation	28
4.	Commissioning	31
4.1	Safety instructions before use	31
4.2	Initial start-up	31
4.3	Testing the socket(s)	31
5.	Connectivity	32
5.1	Configuration tools	32
5.2	Before using the MyEve app	32
5.3	Before using the ACE Service Installer	32
5.4	Configuring the charging station	32
5.4.1	Wired network connection	32
5.4.2	Back office management systems	33
6.	Maintenance	34
6.1	Cleaning	34
7.	Disposal	35
7.1	Decommissioning and returning	35
7.2	Waste electrical and electronic equipment (WEEE)	35

1.1 Disclaimer

This document has been subjected to rigorous technical review before being published. It is revised at regular intervals, and any modifications and amendments are included in the subsequent issues. Although Alfen has made its best efforts to keep the document as precise and up-to-date as possible, Alfen does not assume any liability for defects and damage which results from the use of the information contained herein.

NOTE

This manual is subject to updates and changes. Errors and omissions excepted.

Any deviation to the products as assembled by Alfen including, but not limited to, customer-specific modifications to the product such as the placement of stickers, SIM cards or the usage of different colors (all referred to as 'Customization') may affect the final product, its experience, appearance, quality and / or lifespan (the Customized Product). Alfen is not liable for any damage to, or caused by, the Customized Product if this damage is caused by this applied Customization.

Alfen shall not be liable in any way, for any kind of damage, and the (carry in) warranty for the product and the accessories shall not apply in the following cases:

- Failure to comply with the instructions in this manual in general and with the operating conditions specifically.
- Improper use.
- External damage.
- Installation, commissioning or faulty repair or maintenance by unqualified persons.
- Failures from the grid or the GPS / GPRS provider.
- Modification or configuration of the product or accessories without the knowledge of Alfen.
- Use of spare parts not approved or manufactured by Alfen.
- The charging station is used outside its operating conditions as stated in this manual.
- Situations have occurred that are beyond the control of Alfen(force majeure).
- Malfunction of an open charge point back office.
- Damage to the electrical vehicle.

1.1.1 Improper use

Using the charging station is safe when used as intended. Any other use or changes to the charging station are considered improper use and therefore not permitted. The operator, owner or qualified technician is responsible for any personal injury or material damage arising from improper use.

1.2 Copyright

The reproduction, distribution and utilization of this document, as well as the communication of its contents to other parties without explicit authorization by Alfen N.V. or one of its affiliates, is strictly prohibited. © Alfen N.V.

1.3 Trademarks

Alfen®, Eve®, ICU® are trademarks by Alfen N.V.. Any unauthorized use of the trademarks is therefore illegal.

1.4 Languages

The English version of this document is the original source. Documents in other languages are translations of this source.

1.5 Purpose and intended audience

This manual applies to the Eve Single Pro-line and Eve Single S-line (in this document also indicated as Eve Single, Pro-line, S-line or "charging stations") produced by Alfen ICU B.V., Hefbrugweg 28, 1332AP Almere, the Netherlands, reg.no. 64998363 ("Alfen"). The Alfen Eve Single is intended exclusively for charging electric vehicles and, when installed correctly, may be used by untrained individuals. Follow this manual to install and commission the charging station correctly.

Installation, commissioning and maintenance of this charging station may only be performed by a qualified electrician. It is essential that this person has:

- Expertise on all relevant general and specific rules regarding safety and incident prevention
- Comprehensive knowledge of applicable electrical regulations.
- The ability to identify and foresee risks and avoid potential hazards
- Received and read these installation and operating instructions

1.6 Explanation of text instructions used

Safety warnings and precautions are indicated in this document by means of signal words:

DANGER

"Danger" is the signal word that indicates an imminently hazardous situation that, if not avoided, will result in death or serious injury.

WARNING

"Warning" is the signal word that indicates a potentially hazardous situation that, if not avoided, could result in death or serious injury.

1. SAFETY AND USAGE INSTRUCTIONS

! CAUTION

"Caution" is the signal word that indicates a potentially hazardous situation that, if not avoided, could result in minor or moderate injury.

ℹ NOTE

"Note" is the signal word that provides additional information or information on possible product damage.

1.6.1 Safety symbols

The following warning pictograms are attached to (parts of) the device

Pictogram	Description
	Dangerous voltage

1.7 Software and complementary documentation

The charging station Eve Single uses the firmware version 6.5 at the time of writing.

ℹ NOTE

You must have a wired network connection between the charging station and your laptop, tablet or smartphone to check whether a new firmware version is available.

- The MyEve app notifies if a new firmware version is available.
- The ACE Service Installer does not notify if a new firmware version is available. You need to check this via the menu "Device/Upload new firmware..."

ℹ NOTE

It is possible to request a printed copy of this manual in your language by Alfen at any time. Refer to the contact information for your request.

By means of the following links you can obtain detailed information regarding the Eve Single S-line and Pro-line charging stations.

Installation video
Eve Single S-line



Installation video
on website

Installation video
Eve Single Pro-
line



Installation video
on website

YouTube channel



Alfen - Power to
adapt

providing instal-
lation, service
and information
videos.

Data sheet



Datasheet - Eve
Single Pro-line
and S-line

providing detailed
information on
models, techni-
cal features and
equipment.

Knowledge Base



Knowledge Base

providing service
and procedure in-
structions.

"Eichrecht Adden-
dum"

For German mar-
ket only

Additional infor-
mation document
for the end user
of the Pro-line
models with me-
ters according to
calibration regula-
tions in Germany.



Handbuch Eve
Eichrecht Adden-
dum

1. SAFETY AND USAGE INSTRUCTIONS

Firmware & Error code list



Firmware information and Error codes list

Information on current firmware and list of error messages displayed on Pro-line models, (also provided in the Eve Single user manual).

Declaration of conformity

Please request from your Alfen contact.

Smart Charging configuration Eve Single



Knowledge Base

Document required for configuring Smart Charging features.

Training for Alfen charging stations



Trainings charging stations equipment

class-room trainings provided by Alfen.

Warranty



Carry-in Warranty

The applicable Terms & Conditions of the Alfen Carry-in warranty

NOTE

The operating temperature stated is under the following conditions:

- A maximum charging power of 11 kW is only guaranteed at an ambient temperature above 40 °C and below the stated maximum operating temperature.
- The effect of direct solar radiation on the charging station is excluded.
- The effect of a front cover with another color than RAL9016 is excluded.
- The effect of Customizations applied on the charging station is excluded.
- The stated charging performance is solely applicable to the charging station itself, actual performance is dependent on the vehicle and the grid connection.

1.9 EU Declaration of Conformity

NOTE

The EU declaration of conformity can be requested from Alfen. Please refer to the contact information on the back page of this manual.


1.8 Operating conditions

Operating temperature	-25 °C to +55 °C
Relative atmospheric humidity	5 to 95 %
Electrical safety class	Class I
Degree of protection (casing)	IP55
IK protection (mechanical impact)	IK10

1. SAFETY AND USAGE INSTRUCTIONS

1.10 About this document

This section describes the used symbols, explains their meaning and shows how to use this document.







No.	Description	Symbol	Description
1	Symbol in the top left corner indicates the work step within the installation procedure		Product overview
			Scope of delivery
			Mechanical installation procedure
			Electrical installation procedure
			Additional installation procedure for models with fixed charging cable
			Finishing the installation

- 2 Symbol with number indicates the task to be done within this work step
- Number corresponds to the number within the work step described in the corresponding chapter

12







1. SAFETY AND USAGE INSTRUCTIONS












No.	Description	Symbol	Description
3	Symbols on the left hand side indicate the parts required for this task		Symbols in dark blue color have to be provided by installer
			Symbols in light blue color are part of the Alfen delivery scope.
4	The illustration visualizes the task		Detailed description can be found in the corresponding chapter
5	Symbols in the top right corner indicate the tools required for this task		Symbols in dark blue color have to be provided by installer.
			Symbols in light blue color are part of the Alfen delivery scope.

2. PRODUCT OVERVIEW




2.1 Scope of delivery

The information given in this table refers to illustration A.

 A		
	1x	
	1x	
	1x	


Symbol	Description	Quantity	Symbol	Description	Quantity
	Charging station • Eve Single S-line • Eve Single Pro-line	1		S-line Cable gland M32x1.5	1
	Wall-mount frame	1		S-line Optional cable gland M25x1.5	3
	Torx T20 wrench	1		Pro-line Cable gland M32x1.5	1
	Spacing ring for cable gland M32-M25	1		Pro-line Optional cable gland M25x1.5	2
	RS-485 connector in- cluding TIC protocol con- nections	1		Torx bolt M4x8 mm	6
				Wall plug 4.5-5x8 mm	4

Symbol	Description	Quantity
	Screw 5x50 mm	4
	M8 nut	4
	M8 washer	4
	Counter nut	1
	Reduction ring M32-25	1



Symbol	Description	Quantity
	Installation Manual	1
	User Manual (to be handed over to the customer)	1
	Card with password (recovery) information (to be handed over to the customer)	1

2.2 Legend product overview exterior

The information given in this table refers to illustration B.




2. PRODUCT OVERVIEW

Symbol	Description	Symbol	Description
	Wall-mount frame		Pro-line model (with display) or S-line model (with LED)

	Identification label
---	----------------------

2.3 Legend product overview interior

The information given in this table refers to illustration C.



No.	Description	No.	Description
1	Bolts for front cover	5	Terminal block for the power supply
2	Stud for assembly	6	Terminal block for the fixed charging cable
2a	Screws for wall-mount frame with earth connection	7	RS-485 connector
3	RJ-45 connector	8	SIM cardholder
4	RJ-11 connector		

3.1 Safety announcements

DANGER

Risk of injury and electrocution. Installation, (de)commissioning and maintenance of the charging station may only be performed by a qualified electrician.

DANGER

Risk of injury and electrocution. Installing the charging station incorrectly may result in fatal injury! When working with electricity, failure to comply with relevant regulations can lead to dangerous and life-threatening situations.

DANGER

Risk of electrocution. The electrical system must be disconnected from every power source before performing any installation or maintenance work!

DANGER

Risk of injury and electrocution. The charging station contains electrical components that still contain a charge after being disconnected from the system. Always test with proper equipment there's no residual current before commencing to work.

WARNING

Risk of injuries, explosion or fire. Never install in a potentially explosive atmosphere.

WARNING

Risk of electrocution. Never install in areas prone to flooding without implementing compensatory measures.

WARNING

Risk of injury and electrocution. Installation work may not be carried out during rain or if the air humidity exceeds 95%.

WARNING

Risk of injury and electrocution. The installation must be performed by a qualified electrician who has read this manual and will execute the installation in accordance with the IEC 60364 (Electrical Installations for Buildings) standard.

WARNING

Risk of damage or electrocution. A charging station must always be installed on separate power circuit.

WARNING

Risk of damage or electrocution. Local conditions may affect the installation requirements. Your installation must comply with the standards and regulations of the location (country) where it is installed.

CAUTION

Risk of injury and damage. The installer is always responsible for choosing the correct cable diameter and complying with the relevant standards and legislation.

CAUTION

Risk of injury and damage. The installation and cables should be installed to match the maximum charging current to the input of the charging station. This should assume continuous load.

CAUTION

Risk of injury and damage. Mechanical impact and/or collisions might cause damage to the equipment. Protect products installed in public areas and car park sites.

CAUTION

Risk of damage. Adapters or conversion adapters are not allowed to be used.

3.2 Assembly and installation requirements

When selecting a location to install the charging station, the following criteria must be taken into account:

- Always fully comply with local technical requirements and safety regulations.
- The recommended installation height must be 800 - 1200 mm from the ground to the bottom of the casing.
- The charging port on the vehicle must be easy to reach with the (attached) charging cable.
- The charging station must be installed at a location where the charging cable (approx. 5 - 7.5 m) can be used without placing any tension on the cable.

Ensure that the following requirements for installing the charging station have been met before starting:

- The cable trajectory from the main distributor to the Eve Single must be secured against short-

3. INSTALLING AND CONNECTING

circuiting with a B- or C-type circuit breaker (or other, in accordance with local standards and regulations), or gG type fuses (or other, in accordance with local standards and regulations).

- The cable trajectory must be equipped with 30-mA fault current protection with a type A or B residual current device (RCD).
- The earth leakage circuit breaker must be protected against the maximum current the charging station can process (20 A or 40 A).
- The cable trajectory and the charging station must be part of a TN-S system; the equipment must be earthed at the main distributor or with an earth pin (TT). An energy grid without a neutral conductor is not supported.
- The cable trajectory must be installed in accordance with the usual local professional standards.

Please refer to the following table for safety options and cable cross-sections advised.

Power supply cable: minimum advised cable cross-section (based on assumed max. 50 m cable length):

- 1-phase 3.7 kW charging, 16 A selected per phase: 3 x 4 mm²
- 3-phase 11 kW charging, 16 A selected per phase: 5 x 4 mm²
- 1-phase 7.4 kW charging, 32 A per phase: 3 x 6 mm²
- 3-phase 22 kW charging, 32 A per phase: 5 x 6 mm²

Short-circuit protection:

With circuit breakers:

- 1-phase 16 A (3.7 kW): 1 x 20 A, 1-pole, type B or C
- 3-phase 16 A (11 kW): 1 x 20 A, 3-pole, type B or C
- 1-phase 32 A (7.4 kW): 1 x 40 A, 1-pole, type B or C
- 3-phase 32 A (22 kW): 1 x 40 A, 3-pole, type B or C

With fuses:

- 1-phase 16 A (3.7 kW): 1 x 20 A gG
- 3-phase 16 A (11 kW): 3 x 20 A gG
- 1-phase 32 A (7.4 kW): 1 x 35 A gG
- 3-phase 32 A (22 kW): 3 x 35 A gG

Earth leakage protection (possibly in combination with circuit breaker):

Residual current device: 30 mA type A or B, 4P

- 3.7 kW/11 kW charging: minimum 20 A
- 7.4 kW/22 kW charging: 40 A

Nominal input voltage:

- VL₁-N: 230 V (+/-10 %)
- VL₂-N: 230 V (+/-10 %)
- VL₃-N: 230 V (+/-10 %)
- VL₁-L₂: 400 V (+/-10 %)
- VL₁-L₃: 400 V (+/-10 %)
- VL₂-L₃: 400 V (+/-10 %)
- VPE-N: ≈ 0 V

Nominal frequency: 50 Hz

Grounding:









- TN system: separate PE cable
- TT system: separately installed grounding electrode < 100 Ohm spreading resistance
- IT system: connected to a shared reference (common earth) with other metal parts

3.3 Preparation prior to installation

- View the site and determine the installation location.
- Check the scope of delivery and required parts.
- Read this installation manual before hand.
- Download the data sheet from alfen.com for product-specific information.
- Download the Smart Charging Implementation Guide from knowledge.alfen.com for detailed information on configuring Smart Charging options.

3.4 Installation tools

Symbol	Description
	Pencil or marker
	Wire stripper
	Voltmeter or digital multimeter
	Phillips screwdriver
	Small and large flathead screwdriver

Symbol	Description
	T20 Torx driver
	Ferrules (the diameter of the ferrule depends on the diameter of the power wiring and the construction)
	Spirit level
	Machine drill
	Torque driver (for terminal block connections)
	RJ-11 connector
	RJ-45 connector
	Crimping tool

3.5 Installation procedure prerequisites

NOTE

The following text describes only the wall-mounting installation procedure. The Eve Single can also be mounted on a pole. The pole is an accessory and the installation instruction is provided within its scope of delivery.

NOTE

Install the charging station upright against the wall and / or on the mounting pole. Installations other than this may lead to damage of the charging station.

NOTE

Charging stations which are exposed to the elements will gradually age and/ or discolor. Alfen recommends to place the charging stations in a sheltered environment to optimize the lifetime of the product.

- The installation position must be against a solid, vertical wall.
- In the surroundings of at least 5 m of the installation position there must be no fire hazard.
- The power supply cable must have been routed.
- The power cabinet must have a residual current device (RCD) and a miniature circuit breaker (MCB) to connect the power cable.
- The electrical system must have been disconnected from every power source before performing any installation work.

3.5.1 Data cable options

- Connection to LAN via the RJ-45 connector
- Connection to smart meter via the RJ-11 connector (Belgium and the Netherlands only)
- Connection to smart meter using the TIC protocol (France only; provided within RS-485 connector)
- Connection to external energy meter via the RS-485 connector using the Modbus RTU protocol
- Connection to LAN and smart meter
- No connection to LAN or smart meter


3.6 Mechanical installation procedure

- Take the charging station out of the box.
- Use a non-scratching surface to put the charging station down on to prevent damage.
- Check if all parts listed are provided.

3. INSTALLING AND CONNECTING

3.6.1 Wall-mounting the charging station

1. Determine the position for the charging station at the preferred location:
 - a. Keep 300 mm space clear on all sides around the charging station.
 - b. Choose a comfortable and ergonomically correct height (typically 800 - 1200 mm).
 - c. Use a pencil and a spirit level to mark the top and bottom of the charging station.




3. INSTALLING AND CONNECTING

2. Remove the wall-mount frame from the back of the charging station.
 - a. Remove the front cover and put aside.


NOTE

To prevent damage, do not lay down the charging station on a rough surface. Tip: Use the packaging.




3. INSTALLING AND CONNECTING

3. Unscrew the three Torx T20 screws (will be used again) of the transparent sub-frame and remove the sub-frame from charging station.




3. INSTALLING AND CONNECTING

4. Use the wall-mount frame as a drilling template.
- Use a spirit level to position the wall-mount frame.
 - Mark the drill holes, remove the wall-mount frame.
 - Drill the marked holes with a 8x50 mm drill.




3. INSTALLING AND CONNECTING

5. Install the wall-mount frame.
 - a. Use the 5x50 mm wall plugs and screws provided.




3. INSTALLING AND CONNECTING

6. Use a pencil and a right angle square tool to mark the location for the holes for the wiring: data cable(s) 50 mm below wall-mount, power cable 100 mm below wall-mount. Drill the holes.




3. INSTALLING AND CONNECTING

7. Determine the power supply cable length by holding the charging station in its installation position.
- Determine the power supply cable length by holding the charging station in its installation position.
 - Cut the power cable to the required length.
 - Feed the power cable and data cable(s) approx. 500 mm through the holes.
 - Skin the power cable on a length of approx. 250 mm.



3. INSTALLING AND CONNECTING

8. Hold the charging station carefully while performing the following steps.
 - a. Unscrew the cable gland and screw it to the bottom of the charging station
 - b. Cut the data cable grommet to the size of the diameter of the data cable.




3. INSTALLING AND CONNECTING

9. Feed the power- and data cable through the cable gland and cable grommet. Pull the power and data cable(s) 300 mm into the charging station.


NOTE

Make sure to seal the cable entry carefully with the appropriate grommet. There must be no gaps.



3. INSTALLING AND CONNECTING

10. Mount the charging station on the wall-mount frame with a torque of 10 Nm. Attach the earth wire on the bottom right threaded end of the wall-mount frame. Use M8 washer and nut.




Mechanical installation procedure is finished. Charging station is ready for electrical installation.

3. INSTALLING AND CONNECTING

3.7 Electrical installation procedure


Make sure you know if the charging station needs to be installed as a 3-phase or single phase variant.

1. Connect the power cable to the terminal block according to your product variant 3-phase or single phase shown in the illustration.



3. INSTALLING AND CONNECTING


2. Connect the data cable(s) according to your product variant shown in the illustration.
 - a. Prepare the data cable for the smart meter: Only when connecting the (D)SMR 4.X or higher energy meter remove the green and orange wire pairs of the data cables. Place all 4 wires firmly in the RJ-11 or RJ-45 connector. Make sure that the insulation of the cable is also in the connector.
 - b. Prepare the data cable for the network: Place all 8 wires firmly in the RJ-45 connector. Make sure that the insulation of the cable is also in the connector.
 - c. Prepare the data cable for the external smart meter: Place the 2 wires firmly in the provided RS-485 connector. Make sure that the insulation of the cable is also in the connector.



3. INSTALLING AND CONNECTING


3.7.1 Additional installation procedure for model with fixed charging cable

1. Feed the fixed charging cable through the cable gland.



3. INSTALLING AND CONNECTING


2. Connect the fixed charging cable wires to the terminal block.
 - a. Connect the control power (CP) connector
 - b. Connect the Protective Earth cable (PE) to the terminal.



3. INSTALLING AND CONNECTING


3.8 Finishing the installation

1. Tighten the cable gland firmly so that the power supply cable/charging cable does not have any slack.
 - a. Make sure that all seals are in place or, if they have fallen out, to put them back in place. Otherwise the charging station is not watertight.
 - b. If applicable, reattach the transparent sub-frame
 - c. Models with display: connect the display connector








3. INSTALLING AND CONNECTING

2. Press the front cover back onto the charging station.
 - a. Screw the front cover back onto the charging station with the Torx T20 wrench. Use all six screws for this.



3. INSTALLING AND CONNECTING

3. The electrical installation is finished. The charging station is ready to be commissioned.

4.1 Safety instructions before use

Carry out the following safety instructions before commissioning your charging station:

1. Make sure the charging station is properly connected to the power supply as described in this manual.
2. Make sure the distribution of the power supply is separately protected by an appropriate breaker (automatic or fuse cartridges)
3. Make sure the charging station is installed in accordance with this manual.
4. Make sure the casing is always closed during normal operation.
5. Measure the isolation resistance to make sure the charging cable is not twisted and that the cable, plug and casing do not have any damage.

4.2 Initial start-up

1. Turn on the local power supply.

The charging station will run self diagnostics. The output is tested within a few seconds:

- Testing locks (model with socket)
- Testing internal relays: you will hear these click
- Pro-line models: The display will illuminate briefly
- S-line models: The LED will flash red 3 times; 1 time slowly, 2 times briefly.

The charging station will display the following:

- Pro-line models: The display will show the message 'Charging point is powering up' and then the start screen with logo.
- S-line models: The LED will turn off.

Your charging station is now ready for testing.

4.3 Testing the socket(s)

1. Put the test charging cable or charging cable into the socket. Press firmly.

2. Hold the charge card in front of the RFID-reader to start charging.
 - a. Pro-line models: If you use a charging cable the texts 'Card accepted' and 'Charging in progress' are shown. If you use a test charging cable 'Please plug cable into vehicle' is displayed. An electrical load needs to be connected to simulate the charging process, then the texts 'Card accepted' and 'Charging in progress' are shown.
 - b. S-line models: If you use a charging cable the LED illuminates blue and when charging is in progress it turns to purple. If you use a test charging cable the LED flashes blue. An electrical load needs to be connected to simulate the charging process, then the LED flashes blue when charging is started.

The socket is functional.

3. Hold the charge card in front of the RFID-reader to stop charging.
 - a. Pro-line models: The text 'End of session' is displayed.
 - b. S-line models: The LED flashes blue.
4. Pull out the test charging cable or charging cable. The charging station is now ready for use.

5. CONNECTIVITY

5.1 Configuration tools

The charging station can be accessed and configured:

- via the MyEve app or
- using the ACE Service Installer

The app will guide you step-by-step through the configuration process.

NOTE

Currently the communication between the MyEve app and the charging station is only possible via a wired connection.

5.2 Before using the MyEve app

NOTE

The MyEve app has been designed to be used by the installer / electrician only. Its purpose is to commission and configure Alfen charging stations.

The MyEve app is not intended for use by the charging station end users.

1. Download the MyEve app in Google Play, Apple Store or Windows Store to your laptop, tablet or smartphone.



Google
Play Store



Apple App Store



Microsoft Store

2. You will be requested to create an account.
3. If you have the MyEve app already installed, make sure you update to the latest version. Use the above QR-codes to see if your MyEve app needs to be updated.
4. Make sure the Firewall settings on your laptop, tablet or smartphone are not blocking the MyEve app.

5.3 Before using the ACE Service Installer

1. Download the ACE Service Installer from the Alfen website to your laptop:

<https://alfen.com/en-gb/search-downloads>

2. Request an account at this e-mail address: ace.aftersales@alfen.com.

NOTE

It may take some days until you receive the login-data.

3. If you have the ACE Service Installer already installed, make sure you have the latest version. If updates are available, you will be asked to update when you log in.
4. Make sure the firewall settings on your device are not blocking the ACE Service Installer.

5.4 Configuring the charging station

5.4.1 Wired network connection

How to establish a wired network connection by connecting the charging station to your device using an UTP (Ethernet) cable:

The minimum requirement is a CAT5 UTP (Ethernet) cable

NOTE

For the use of a smartphone or tablet an adapter such as a USB-C to Ethernet or Lightning to Ethernet is required.

1. Log into the MyEve app or the ACE Service Installer.
2. Connect the UTP (Ethernet) cable to your router or directly to the charging station.
3. Connect the UTP (Ethernet) cable with the corresponding port.
4. Connect your device to the switch or router or directly to the charging station.
5. Select your charging station from the list in the MyEve app or the ACE Service Installer.

NOTE

If the charging station(s) is (are) not detected automatically, the MyEve app or the ACE Service Installer might be blocked by the Firewall on your laptop, tablet or smartphone. Check the settings of your laptop, tablet or smartphone and try again.

6. Enter the provided password.
The network connection has now been established. Via the MyEve app or the ACE Service Installer you can configure the settings

7. After finishing the configuration, hand over the card with password (recovery) information to the customer.

5.4.2 Back office management systems

If additional services by a back-office provider have been purchased, the charging station has been configured ex-factory to connect to the selected back-office management system.

NOTE

A connection with a back-office management system can only be established if arrangements with the supplier of this system have been made. The service of third parties is not provided by Alfen.

NOTE

If the charging station is set to connect with a back office management system, it will do so directly and automatically.

NOTE

Manually configuring and connecting to a back-office management system can be done with the MyEve app. A SIM card needs to be installed during installation. If you do not have a SIM card, please contact your back-office provider.

NOTE

If a mobile communication (SIM card) Internet connection has been purchased, the charging station is already equipped with a SIM card and will automatically connect, once the charging station is being commissioned.

6. MAINTENANCE

6.1 Cleaning

Maintaining the casing of the charging station:

- Annual cleaning, using water and a mild soap. Polish the charging station with a wax that is also suitable for cars.

NOTE

The casing of the charging station can be damaged. Do not use any aggressive cleaning agents, high-pressure cleaner, scouring pads or similar.

7.1 Decommissioning and returning

WARNING

Risk of injury and electrocution. Installation, (de)commissioning and maintenance of the charging station must only be performed by a qualified electrician.

For returning charging equipment to Alfen Charging Equipment, create a 'Request for Service' ticket at support.alfen.com. For further instructions please view [How do I return a charging station to have it repaired in Alfen's manufacturing facility \(Carry-in\)?](#) You will receive all shipping instructions within the ticket.

7.2 Waste electrical and electronic equipment (WEEE)



Electrical and electronic equipment contains materials, components and substances that may be hazardous and present a risk to human health and the environment if not handled correctly.

Equipment marked with the illustrated crossed out wheeled bin is electrical and electronic equipment. The crossed out wheeled bin indicates that this waste must be collected separately and must not be discarded together with household waste.

Refer to your local authority for collection schemes under which residents can dispose waste electrical and electronic equipment at a recycling center or other collection points.

Contact

Alfen ICU B.V.
Hefbrugweg 28
1332 AP Almere
The Netherlands

P.O. box 1042
1300 BA Almere
The Netherlands

Alfen Knowledge Base:	knowledge.alfen.com
Alfen Service Portal:	aftersales.alfen.com
Tel. Service:	+31 (0)36 54 93 402
Website:	alfen.com